

**BANKS COUNTY COMMUNICATIONS
GRADY FIRE RADIO TOWER
RFP #2011-COMMUNICATIONS-1
ADDENDUM / CLARIFICATION # 4**

QUESTIONS SUBMITTED BY DALEY TOWER

**ANSWERS PROVIDED BY BANKS COUNTY COMMUNICATIONS WITH AID
FROM THE BANKS COUNTY E-911 MAINTENANCE PROVIDER**

1. Daley Tower posed the following question.

From: Jeremy Hollier [mailto:jeremy@daleytower.com]
Sent: Friday, September 02, 2011 2:55 PM
To: Deidra Moore
Subject: Tower Bid

Will we need Engineered drawings of the grounding and site build?

Our Answer: The tower structural design and tower foundation must be designed by a professional engineer and documented (sealed) as such per the paragraph on Page 8, Section 2B of the RFP.

A site drawing showing the ground system, fencing, foundation, etc placement as it related to other fixed structures on the site should be provided but does not have to be professionally prepared, signed or sealed.